



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

2/21/2017

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/17/2017. The results are tabulated on the attached data pages for the following client designated project:

Point Pleasant BOE-Memorial MS, PR-161219-1221

The reference number for these samples is EMSL Order #011701297. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701297

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 02/17/17 1:40 PM

Project: Point Pleasant BOE-Memorial MS, PR-161219-1221

Analytical Results

Client Sample Description 39-0217-MMS01
 Main-Office-Sink **Collected:** 2/17/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS02
 Nurse-Sink-Bathroom **Collected:** 2/17/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS03
 Nurse-Sink **Collected:** 2/17/2017 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.10	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS04
 Guidance-Sink **Collected:** 2/17/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS05
 DW-&th0Grade-By-107 **Collected:** 2/17/2017 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS06
 Left-WF-7th-Grade-New-Wing **Collected:** 2/17/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS07
 Right-WF-7th-Grade-New-Wing **Collected:** 2/17/2017 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701297

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 02/17/17 1:40 PM

Project: Point Pleasant BOE-Memorial MS, PR-161219-1221

Analytical Results

Client Sample Description 39-0217-MMS08
Ice-Machine
Collected: 2/17/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS09
DW-Gym-Hall-Girls-Side
Collected: 2/17/2017 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS10
DW-Gym-Hall-Boys-Side
Collected: 2/17/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS11
Caf.-WF
Collected: 2/17/2017 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS12
Kitchen-Sink
Collected: 2/17/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.44	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS13
Kitchen-Sink
Collected: 2/17/2017 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS14
Kitchen-Sink-Handwashing
Collected: 2/17/2017 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.48	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701297

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 02/17/17 1:40 PM

Project: Point Pleasant BOE-Memorial MS, PR-161219-1221

Analytical Results

Client Sample Description 39-0217-MMS15
 Kitchen-Sink-Dishwasher
Collected: 2/17/2017 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS16
 WF-Across-From-Home-EC
Collected: 2/17/2017 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS17
 Home-EC-Sink
Collected: 2/17/2017 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS18
 Home-EC-Sink
Collected: 2/17/2017 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.46	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS19
 Home-EC-Sink
Collected: 2/17/2017 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.01	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS20
 Home-EC-Sink
Collected: 2/17/2017 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.87	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS21
 Home-EC-Sink
Collected: 2/17/2017 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.66	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701297

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 02/17/17 1:40 PM

Project: Point Pleasant BOE-Memorial MS, PR-161219-1221

Analytical Results

Client Sample Description 39-0217-MMS22
 DWF-Cardio-Room
Collected: 2/17/2017 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS23
 WF-6th-Grade-Boys-Side
Collected: 2/17/2017 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS24
 WF-6th-Grase-Girls-Side
Collected: 2/17/2017 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS25
 WF-2nd-Floor-By-Rm-202
Collected: 2/17/2017 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS26
 WF-2nd-Floor-By-Rm207
Collected: 2/17/2017 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS27
 WF-2nd-Floor-By-Rm-212
Collected: 2/17/2017 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Client Sample Description 39-0217-MMS28
 WF-Left-By-Rm-214
Collected: 2/17/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011701297

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 02/17/17 1:40 PM

Project: Point Pleasant BOE-Memorial MS, PR-161219-1221

Analytical Results

Client Sample Description 39-0217-MMS29 **Collected:** 2/17/2017 **Lab ID:** 0029
 WF-Right-By-Rm214

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/20/2017	AE	2/20/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)