



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 658-4571 Email: EnvChemistry2@emsl.com

Attn:

Randi Wheeler
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

1/18/2017

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/3/2017. The results are tabulated on the attached data pages for the following client designated project:

Pt. Pleasant - Admin Bldg

The reference number for these samples is EMSL Order #011700017. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700017

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Admin Bldg

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB01 Bathroom/ Kitchen Sink (100)		12/29/2016		0001				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	15.7	1.00	µg/L	1/17/2017	AE	1/17/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB02 Kitchen Sink (97)		12/29/2016		0002				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	8.45	1.00	µg/L	1/17/2017	AE	1/17/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB03 Mens Bathroom Sink (left - 99)		12/29/2016		0003				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	35.9	1.00	µg/L	1/17/2017	AE	1/17/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB04 Mens Bathroom Sink (right - 99)		12/29/2016		0004				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	58.2	1.00	µg/L	1/17/2017	AE	1/17/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB05 Water Fountain (96)		12/29/2016		0005				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	2.94	1.00	µg/L	1/17/2017	AE	1/17/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB06 Womens Bathroom Sink (left 98)		12/29/2016		0006				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	4.53	1.00	µg/L	1/17/2017	AE	1/17/2017	SM
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
38-1229-AB07 Womens Bathroom Sink (right 98)		12/29/2016		0007				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	6.56	1.00	µg/L	1/17/2017	AE	1/17/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700017

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Randi Wheeler**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (856) 616-9517
 Received: 01/03/17 10:00 AM

Project: Pt. Pleasant - Admin Bldg

Analytical Results

Client Sample Description 38-1229-AB08 *Collected:* 12/29/2016 *Lab ID:* 0008
 Bathroom Sink (95)

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	11.3	1.00	µg/L	1/17/2017	AE	1/17/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

Point Pleasant Lead Results
Results in excess of 15 ug/L

Site Location - Admin Building 2100 Panther Path
LAB : EMSL Analytical Inc
Analysis Date: 1/17/2017

		First Draw Results	Remedial Action taken
<u>Sample Description</u>	<u>Building Location</u>		
38-1229-AB01	Bathroom Sink (tag#100)	15.7	Sink disconnected filter to be put on , retest
38-1229-AB03	Mens Bathroom Sink (tag 99 left)	35.9	Sink marked "Do not Drink" to be used for hand washing only , filter to be put on ,retested
38-1229-AB04	Mens Bathroom Sink (tag 99 right)	58.2	Sink disconnected filter to be put on, retested